ಅಭಿಯಾನ ಅಡಿಯಲ್ಲಿ ಅನುದಾನದ ಲಭ್ಯತೆಯನ್ನಾಧರಿಸಿ, ಹಂತ ಹಂತವಾಗಿ ಶೌಚಾಲಯಗಳನ್ನು ನಿರ್ಮಾಣ ಮಾಡಲು ಕ್ರಮ ಕೈಗೊಳ್ಳಲಾಗುವುದು

ಕುಡಿಯುವ ನೀರಿನಲ್ಲಿ ಫ್ಲೋರೈಡ್ ಅಂಶ

1455(1969); ಶ್ರೀ ಕ್ಯಾತಸಂದ್ರ ಎನ್.ರಾಜಣ್ಣ (ಮಧುಗಿರಿ)

ಅ) ಮಧುಗಿರಿ ತಾಲ್ಲೂಕಿನ ಗ್ರಾಮಗಳಲ್ಲಿ ಕುಡಿಯುವ ನೀರಿನಲ್ಲಿ ಫ್ಲೋರೈಡ್ ಅಂಶ ಜಾಸ್ತಿ ಇರುವ ವಿಚಾರ ಸರ್ಕಾರದ ಗಮನಕ್ಕೆ ಬಂದಿದೆಯೇ; ಹಾಗಿದ್ದಲ್ಲಿ ಇಂತಹ ಗ್ರಾಮಗಳ ಸಂಖ್ಯೆ ಎಷ್ಟು (ವಿವರ ನೀಡುವುದು);

ಆ) ಫ್ಲೋರೈಡ್ ಅಂಶಯುಕ್ತ ನೀರನ್ನು ಉಪಯೋಗಿಸಿದ್ದರಿಂದ ಸ್ಥಳೀಯ ಜನರು ಅನಾರೋಗ್ಯದಿಂದ ಬಳಲುತ್ತಿರುವ ವಿಚಾರ ಸರ್ಕಾರದ ಗಮನಕ್ಕೆ ಬಂದಿದೆಯೇ;

ಇ) ಹಾಗಿದ್ದಲ್ಲಿ, ಶುದ್ಧ ಕುಡಿಯುವ ನೀರು ಪೂರೈಕೆಗೆ ಸರ್ಕಾರ ಕೈಗೊಂಡಿರುವ ಕ್ರಮಗಳೇನು (ವಿವರ ನೀಡುವುದು)?

ಶ್ರೀ ಹೆಚ್.ಕೆ. ಪಾಟೀಲ್ (ಗ್ರಾ. ಮತ್ತು ಪಂ. ರಾಜ್ ಸಚಿವರು)

ಅ) ಬಂದಿದೆ.

43 ಗ್ರಾಮಗಳ ವಿವರಗಳನ್ನು ಅನುಬಂಧ–1ರಲ್ಲಿ ನೀಡಿದೆ.

ಆ) ಬಂದಿದೆ.

ಇ) ಪರ್ಯಾಯ ಸುರಕ್ಷಿತ ಜಲಮೂಲವಿಲ್ಲದಿರುವ ಮತ್ತು ತೀವ್ರ ಕುಡಿಯುವ ನೀರಿನ ಗುಣಮಟ್ಟದ ಸಮಸ್ಯೆಯಿರುವಡೆ ಶುದ್ಧ ಕುಡಿಯುವ ನೀರು ಪೂರೈಕೆಗಾಗಿ ಪ್ರಸಕ್ತ ಸಾಲಿನಲ್ಲಿ 27 ಶುದ್ಧ ಕುಡಿಯುವ ನೀರಿನ ಘಟಕಗಳನ್ನು ಅಳವಡಿಸಲು ಕ್ರಮ ಕೈಗೊಂಡಿದೆ. ಉಳಿದ 16 ಜನವಸತಿಗಳಿಗೆ ಪರ್ಯಾಯ ಸುರಕ್ಷಿತ ಜಲಮೂಲ ಒದಗಿಸಿ ಕುಡಿಯುವ ನೀರಿನ ವ್ಯವಸ್ಥೆ ಕಲ್ಪಿಸಲು ಜಿಲ್ಲಾ ಪಂಚಾಯಿತಿ ಕ್ರಮವಹಿಸಿದೆ. ವಿವರಗಳನ್ನು ಅನುಬಂಧ–2ರಲ್ಲಿ ನೀಡಿದೆ.

ANNEXURE 1 TO LAQ 1969

Sno	PanchayatName	VillageName	HabitationName	Contamination
1	BEDATTUR	KYATHAGONDANAHALLI	KYATHAGONDANAHALLI	Fluoride (Level- 1.72 mg/l) Iron (Level- 0.90 mg/l)
2	BEDATTUR	NARAPPANAHALLI	NARAPPANAHALLI	Fluoride (Level- 1.70 mg/l)
3	BEDATTUR	SAPPENAHALLU	SAPPENAHALU	Fluoride (Level- 2.05 mg/l)
4	BEDATTUR	SHRAVANAGUDI	SHRAVANAGUDI	Fluoride (Level- 2.70 mg/l)
5	BUAVARA	KARAMARADI	KARAMARADI	Fluoride (Level- 1.75 mg/l)
6	BUAVARA	MARABAHALLI	MARABAHALLI	Fluoride (Level- 3.00 mg/l)
7	BUAVARA	SHETTIHALLI	SHETTIHALU	Fluoride (Level- 1.74 mg/l)
8	BUAVARA	SOGENAHLLI	GOLLARAHAATTI-2	Fluoride (Level- 1.80 mg/l)
9	BUAVARA	VEERANNAHALLI THANDA	VEERANNAHALLI TANDA	Fluoride (Level- 1.68 mg/l) Nitrate (Level- 50.00 mg/l)
10	BRAHMASAMUDRA	BRAHMASAMUDRA	DINNEGOLLARAHATTI	Fluoride (Level- 2.00 mg/l)
11	BRAHMASAMUDRA	BRAHMASAMUDRA	HALEGOLLARAHATTI	Fluoride (Level- 2.10 mg/l)
12	BRAHMASAMUDRA	MUDDANERALEKERE	OBASAPPANAPALYA	Fluoride (Level- 2.40 mg/l)
13	BRAHMASAMUDRA	MUDDANERALEKERE	MUDDANERALEKERE	Fluoride (Level- 1.60 mg/l)
14	BRAHMASAMUDRA	SHOBENAHALU	SHOBENAHALU	Fluoride (Level- 3.00 mg/l)
15	BYALYA	EJJIHALU	EJJIHALU	Fluoride (Level- 3.00 mg/l)
16	BYALYA	GAGRAHARA	GAGRAHARA	Fluoride (Level- 2.39 mg/l)
17	BYALYA	GAGRAHARA	KULABAGILAPALYA	Fluoride (Level- 3.50 mg/l) Iron (Level- 2.00 mg/l)
18	CHANDRAGIRI	CHANDRAGIRI	SHANKARAPURA	Fluoride (Level- 1.80 mg/l)
19	CHANDRAGIRI	JAKKENAHALLI	BALEHALU	Fluoride (Level- 2.20 mg/l)
20	CHIKKAMALUR	HOSAHALLU	HOSAHALU	Fluoride (Level- 4.00 mg/l)

21	CHIKKANALUR	KALLENAHALLI	KALLENAHALLI	Fluoride (Level- 3.00 mg/l)
22	CHIKKANALUR	VENKATAPURA	THIGALARAHALLI	Fluoride (Level- 3.00 mg/l)
23	CHINAKAVAJRA	CHINNAKAVAJARA	KEREGALAPALYA J.H.C	Fluoride (Level- 2.20 mg/l), Iron (Level- 30.00 mg/l)
24	CHINAKAVAJRA	CHINNAKAVAJARA	MADAGANAHATTI	Fluoride (Level- 2.50 mg/l)
25	CHINAKAVAJRA	HARIHARAROPPA	HARIHARAROPPA	Fluoride (Level- 2.40 mg/l)
26	CHINNENAHLU	HASAHALLI	HASAHALLI	Fluoride (Level- 2.50 mg/l)
27	CHINNENAHLU	VEERACINENAHALLI	VEERACINENAHALLI	Fluoride (Level- 2.30 mg/l)
28	DABBEGATTA	DABBEGATTA	DOBBEGATTA	Fluoride (Level- 1.60 mg/l)
29	DABBEGATTA	THONACHAGONDANAHALLI	THONACHAGONDANAHALLI	Fluoride (Level- 2.90 mg/l)
30	GANJALAGUNTE	GANJALAGUNTE	HALEHATTI	Fluoride (Level- 2.70 mg/l)
31	GANJALAGUNTE	MALLENAHALLI	MALLENAHALLI	Fluoride (Level- 2.50 mg/l), Iron (Level- 1.93 mg/l)
32	GANJALAGUNTE	SHAMBONAHALLY	SHAMBONAHALLICROSS	Fluoride (Level- 1.80 mg/l), Iron (Level- 3.00 mg/l)
33	GONDHALU	DODDAGALIHALLI	DODDAGALIHALLI	Fluoride (Level- 1.70 mg/l)
34	HOSAKERE	AVARGALLU	AVARGALLU	Fluoride (Level- 2.60 mg/l)
35	KODAGADALA	SUNNAVADI	SUNNAVADI	Fluoride (Level- 1.90 mg/l)
36	KONDAVADI	NAVILADAKU	NAVILADAKU	Fluoride (Level- 2.00 mg/l)
37	MARUVEKERE	BANDREHALLI	BANDREHALLI	Fluoride (Level- 2.50 mg/l)
38	MIDIGESHI	HANUMANTHAPURA	CATRAPHAYALA	Fluoride (Level- 2.70 mg/l)
39	MIDIGESHI	HANUMANTHAPURA	THOTADAMADAGU	Fluoride (Level- 2.30 mg/l)
40	NERALEKERE	GAMPALAHALLI	GAMPALAHALLI	Fluoride (Level- 2.50 mg/l)
41	PURAVARA	DODDAHOSAHALLI	DODDAHOSAHALLI	Fluoride (Level- 1.60 mg/l)
42	PURAVARA	HARALLAPURA	HARALLAPURA	Fluoride (Level- 2.20 mg/l), Iron (Level- 30.00 mg/l)
43	SIDDAPURA	VADERAHALLI	VADERAHALLI	Fluoride (Level- 3.30 mg/l)

ANNEXURE 2 TO LAQ -1969

Sl.No	District Name	Block Name	Panchayat Name	Village Name	Habitation Name	Population	Contamination
1	2	3	4	5	6	7	8
1	TUMKUR	MADHUGIRI	BEDATTUR	KYATHAGONDANAHALLI	KYATHAGONDANAHALLI	552	Fluoride (Level- 1.72 mg/l) , Iron (Level- 0.50 mg/l)
2	TUMKUR	MADHUGIRI	BUAVARA	SHETTIHALLI	SHETTIHALLI	876	Fluoride (Level- 1.74 mg/l)
3	TUMKUR	MADHUGIRI	BIJAVARA	VEERANNAHALLI THANDA	VEERANNAHALLI TANDA	515	Fluoride (Level- 1.68 mg/l) , Nitrate (Level- 50.00 mg/l)
4	TUMKUR	MADHUGIRI	BRAMHASAMUDRA	BRAMHASAMUDRA	DINNEGOLLARAHATTI	500	Fluoride (Level- 2.00 mg/l)
5	TUMKUR	MADHUGIRI	BRAMHASAMUDRA	BRAMHASAMUDRA	HALEGOLLARAHATTI	523	Fluoride (Level- 2.10 mg/l)
6	TUMKUR	MADHUGIRI	BRAMHASAMUDRA	MUDDANERALEKERE	DHASAPPANAPALYA	521	Fluoride (Level- 2.40 mg/l)
7	TUMKUR	MADHUGIRI	BRAMHASAMUDRA	MUDDANERALEKERE	MUDDANERALEKERE	817	Fluoride (Level- 1.60 mg/l)
8	TUMKUR	MADHUGIRI	BYALYA	G.AGRAHARA	MULABAAGILAPALYA	493	Fluoride (Level- 3.50 mg/l) , Iron (Level- 2.00 mg/l)
9	TUMKUR	MADHUGIRI	CHIKKAMALUR	JAKKENAHALLI	HOSAHALLI	578	Fluoride (Level- 4.00 mg/l)
10	TUMKUR	MADHUGIRI	CHIKKAMALUR	KALLENAHALLI	KALLENAHALLI	1011	Fluoride (Level- 3.00 mg/l)
11	TUMKUR	MADHUGIRI	CHIKKAMALUR	KALLENAHALLI	THIGALARAHALLI	818	Fluoride (Level- 3.00 mg/l)

12	TUMKUR	MADHUGIRI	CHINAKAVAJARA	CHINAKAVAJARA	MADAGANAHATTI	667	Fluoride (Level- 2.50 mg/l)
13	TUMKUR	MADHUGIRI	CHINNENAHLU	HASAHALLI	HASAHALU	500	Fluoride (Level- 2.50 mg/l)
14	TUMKUR	MADHUGIRI	CHINNENAHLU	VEERACINENAHALLI	VEERACINENAHALLI	500	Fluoride (Level- 2.30 mg/l)
15	TUMKUR	MADHUGIRI	DABBEGATTA	DABBEGATTA	DOBBEGATTA	1342	Fluoride (Level- 1.60 mg/l)
16	TUMKUR	MADHUGIRI	DABBEGATTA	THONACHAGONDANAHLU	THONACHAGONDANAHALU	581	Fluoride (Level- 2.90 mg/l)
17	TUMKUR	MADHUGIRI	GANJALAGUNTE	GANJALAGUNTE	HALEHATTI	500	Fluoride (Level- 2.70 mg/l)
18	TUMKUR	MADHUGIRI	GANJALAGUNTE	SHAMBONAHALLY	SHAMBONAHALLICROSS	250	Fluoride (Level- 1.80 mg/l) , Iron (Level- 3.00 mg/l)
19	TUMKUR	MADHUGIRI	GONDIHALLI	AVARGALLU	AVARGALLU	616	Fluoride (Level- 2.80 mg/l)
20	TUMKUR	MADHUGIRI	KODAGADALA	SUNNAVADI	SUNNAVADI	500	Fluoride (Level- 1.90 mg/l)
21	TUMKUR	MADHUGIRI	KONDAVADI	NAVILADAKU	NAVILADAKU	769	Fluoride (Level- 2.00 mg/l)
22	TUMKUR	MADHUGIRI	MARUVEKERE	BANDREHALLI	BANDREHALU	838	Fluoride (Level- 2.50 mg/l)
23	TUMKUR	MADHUGIRI	MIDIGESHI	HANUMANTHAPURA	THOTADAMADAGU	500	Fluoride (Level- 2.30 mg/l)
24	TUMKUR	MADHUGIRI	NERALEKERE	GAMPALAHALLI	GAMPALAHALU	660	Fluoride (Level- 2.50 mg/l)
25	TUMKUR	MADHUGIRI	PURAVARA	DODDAHOSAHALU	DODDAHOSAHALLI	1837	Fluoride (Level- 1.60 mg/l)
26	TUMKUR	MADHUGIRI	PURAVARA	HARALLAPURA	HARALLAPURA	433	Fluoride (Level- 2.20 mg/l) , Iron (Level- 30.00 mg/l)
27	TUMKUR	MADHUGIRI	SIDDAPURA	VADERAHALLI	VADERAHALLI	959	Fluoride (Level- 3.00 mg/l)